

BY REGD. POST A/D

GOVERNMENT OF MAHARASHTRA

NO./53 /FA
Tel. No.2687 2828
Fax No. 2687 0325

OFFICE OF THE FIRE ADVISOR

C/o MIDC (Fire Department),
Udyog Sarthi Building, Mahakali
Caves Road, Andheri (E),
Mumbai -400 093.

Dated : 28/2/2008

To,
The Commissioner & Director, Municipal Administration,
Government Transport Service Building,
3rd Floor, Sir Pochkhanwala Road, Worli,
Mumbai-400 030.
Fax No.24946880 / 24986503

Sub: Procurement of Water Mist Appliances being
Promoted by Company called Advance Fire
Fighting Technology.

Ref: Letter No. नप्र/कक्ष-४३/अग्निशमन मान्यता/२००८
१२ फेब्रुवारी, २००८ received from Dy. Director,
Municipal Administration..

Sir,

This has reference to your letter under reference. We would like to place on record that the subject mentioned product is not designed as per the specifications prescribed either by the Bureau of Indian Standards or British Standards or Australian Standards or any other International Standards. This product was recommended by this office 3 years before to the Nagpur Municipal Corporation as per their oral commitment to produce the necessary specifications. However they have failed to produce the same. Till such time, the product is proved to be retrofitting to the stipulated Indian Standards or International Standards, it is not advisable to encourage it the procurement of their product under the proprietary Brand Name, in particular, as a replacement to the existing mobile appliances those are supplied with conventional Fire Pumps or high-pressure- low-pressure or ultra high-pressure technologies. This letter is being endorsed to all the Chief Fire Officers and officer in-charge of Fire Brigades for further necessary action. You are also requested to please direct all the Municipal Councils which are directly under your administrative control.

Thanking you,

Yours faithfully,

(M.V. Deshmukh)

Director, Maharashtra Fire Services &
Fire Advisor,
Government of Maharashtra

Copy submitted to the Principal Secretary, Urban Development Deptt.,
Mantralaya, Mumbai.

Copy f.w.cs. to

- (1) The Dy. Secretary (Shri Adivarekar)
- (2) The Chief Fire Officer, Mumbai.