

महाराष्ट्र शासन

क्र.मअसे-२०२१/१०/१५५५

दूरध्वनी: २६६७७५५५

फॅक्स : २६६६०२८७

Email : supdt@mahafireservice.gov.in

Website: www.mahafireservice.gov.in

महाराष्ट्र अग्निशमन सेवा संचालनालय,

महाराष्ट्र अग्निशमन सेवा अकादमी,

विद्यानगरी, हंस भुग्रा मार्ग,

सांताक्रूझ-पूर्व, मुंबई-४०० ०९८.


दिनांक : २६ ऑक्टोबर, २०२१.

: परिपत्रक :

विषय : सणासुदीच्या काळात अग्निसुरक्षा व अग्निप्रतिबंधाबाबत उपाययोजना करणे.

संदर्भ : अग्निशमन सल्लागार, केंद्र शासन, केंद्रीय गृह मंत्रालय, नवी दिल्ली यांचे परिपत्रक
क्र. No.VIII-11011/03/2021-DGCD(F), दि.१२.१०.२०२१

मागील काही वर्षांत असे निदर्शनास आले आहे की, सणासुदीच्या काळात विशेष करून दिवाळी सणाच्या वेळी सण साजरा करण्यासाठी स्थानिक जनता आणि विविध संस्थाकडून तात्पुरते मंडप/तात्पुरती रचना यांची उभारणी केली जाते.. या मंडपांना /तात्पुरती तयार केलेली रचना यांना आग लागून घटना घडतात व त्यामुळे मोठ्या प्रमाणात जिवित व वित्तीहानी होते. सदर मंडप /तात्पुरती तयार केलेली रचना यांची देखभाल करण्यासाठी अग्निसुरक्षितेच्या दृष्टीने भारतीय मानक ब्युरो यांनी (आयएस८७५८ नुसार) विहित केलेल्या मार्गदर्शक तत्वावरनुसार तयार केलेली उपाययोजना अंमलात आणावी असे अग्निशमन सल्लागार, केंद्र शासन, केंद्रीय गृह मंत्रालय, नवी दिल्ली यांनी त्यांच्या उपरोक्त परिपत्रकान्वये कळविले आहे. सदर परिपत्रकामध्ये नमूद केलेल्या सूचनांचे काटेकोरपणे पालन करून त्या अमलांत आणाव्यात. सदर परिपत्रकाची प्रत सोबत जोडण्यांत आली आहे.



(एस.एस.वारीक)

संचालक

महाराष्ट्र अग्निशमन सेवा

- प्रत :
१. मा.प्रधान सचिव-२, नगर विकास विभाग, मंत्रालय, मुंबई-४०० ०३२ यांना माहितीसाठी सादर.
 २. मा.मुख्य कार्यकारी अधिकारी/व्यवस्थापकीय संचालक, विशेष नियोजन प्राधिकरणे.
 ३. आयुक्त तथा संचालक, नगरपालिका प्रशासन संचालनालय, वरळी, मुंबई ४०० ०३०.
 ४. सर्व विभागीय आयुक्त.
 ५. सर्व जिल्हाधिकारी.
 ६. आयुक्त, सर्व महानगरपालिका.
 ७. मुख्याधिकारी सर्व नगर परिषदा / नगर पंचायती.
 ८. सर्व नागरी स्थानिक स्वराज्य संस्था व विशेष नियोजन प्राधिकरणे यांचे मुख्य अग्निशमन अधिकारी व प्रभारी अग्निशमन अधिकारी.

1264

14 OCT 2021

No VIII-11011/03/2021-DGCD(F)

Ministry of Home Affairs

Directorate General FS, CD & Home Guards

East Block – VII, Level – VII,
R.K. Puram, New Delhi – 110 066

Dated the 12th October, 2021

Seen by :

Director :

To

S.I. :

All the Heads of Fire Services in the States/UTs

O.S. :

Subject :

Fire Pre-cautions and Safety Measures during Festival Seasons : Reg.

Action by :

Sir,

During festival seasons temporary structures and pandals are being constructed by the local public and organizations to celebrate the functions. These pandals and temporary structures required to be made/protected in accordance with Indian Standards (IS) to ensure fire safety.

2. In the past many fire incidents have been reported in the temporary structures/pandals. To avoid such incidents during festivals, the following suggestions/guidelines in accordance with IS Standard (IS8758) may be ensured :-

- i) Each temporary structure shall be permitted only in Fire Zones No. 1 & 2 as the case may be, according to the purpose for which these are to be used for a limited period and the provisions of this standard shall be complied with.
- ii) Such temporary structures shall be completely removed on the expiry of the period specified in the permit.
- iii) The materials for such constructions shall preferably be of non combustible or fire resistance type. The materials used for the decoration shall not generate toxic / fumes.
- iv) The main structures shall be erected with at least 100 mm diameter post of non-combustible material or wooden post and the rest may be of lighter poles and trusses tied / screwed properly with steel wire.
- v) The height of the ceiling of the structure or pandal from the ground shall not, in any case, be less than 3 Meter.
- vi) No decorative paper/synthetic material shall be used anywhere in the pandal / structure.

Contd...P/2

to make
to circulate

- vii. All fabrics, decorative clothing used in the constructions and decoration of the structure shall conform to IS 15612 (Part I) and IS 15741
- viii. No nylon or synthetic ropes shall be used anywhere in the structures. Only ropes made of coir, manila or coconut fibers shall be treated with fire retardant solutions.
- ix. Temporary structures shall be adequately guyed / braced and made secure to withstand a wind pressure.

3. It is requested to issue necessary directions to all concerned for strict compliance of the above guidelines before issuing the necessary permission to construct any temporary structure/pandal.

Yours faithfully



(D. K. Shami)
Fire Adviser
Tel. 2671 2951